



East Toba River and Montrose Creek Hydroelectric Project Independent Environmental Monitor's Report

Powell River Transmission Line Weekly Report for Period March 13 to March 19, 2010

Weather: March 13 – partly sunny
 March 14 – partly sunny
 March 15 – sunny
 March 16 – overcast with intermittent rain
 March 17 – overcast
 March 18 – overcast
 March 19 – overcast

Fisheries observations: None.

Wildlife observations:

Action Items:

Independent Environmental Monitor Activities

Construction activities:

Saltery Bay Substation

- Finished grouting steel bases
- Added additional grounds for disconnect motors
- Temporarily energized substation
- Finished final connection of incoming conductor in substation
- Installed warning signs

PKS

- Started installing overhead danger signs at all areas of transmission line
- Fixed drainage issues at 53/5
- Tested power line carrier
- Changed out backfill in the Daniels Valley

- Deactivating road in the Daniels and Jim Brown valley

Non-compliance activities and mitigation measures: None.

Action Items:

Date	Item number	Location	Description	Mitigation measures	Risk/priority	Status	Date completed, photo #
August 27 2009		Sites 128/6, 129/3,	Remove construction debris as specified		Low	Ongoing, to be assessed at completion	
November 6, 2009		Saltery Bay sector	Remove wood waste and puncheon from drainage channels at sites 140/1 to 141/1		Medium	Ongoing	
December 2, 2009		Jim Brown Sector	Clean culverts at mile 1.75 Jim Brown and at intersection of Jim Brown and Falls Mains		Medium	Ongoing	
December 18, 2009		Third Lake Sector	Provide geo technical assessment for work required at site 132/8 and carry out work identified		High	ASAP	Site assessment completed, awaiting report
February 15 to 17 2010		Daniels and Jim Brown sectors	Correct drainage issues at the following sites: 56/4, 57/4, 63/1, 63/6, 66/4		Medium to high	ASAP	
February 15 to 17 2010		Daniels and Jim Brown sectors	Remove construction debris on or around the following sites: 54/5, 56/2, 57/2, 59/2, 59/5, 60/2 and adjacent pull station, 62/5, 64/4, 66/4, 74/4, 78/3, 82/2		Low to medium	ASAP	
February 24 2010		All sectors	End haul all damaged culverts removed as part of the final deactivation		Low	ASAP	

Fisheries sensitive activities and mitigations: None.

Sampling results: None.